



DEPARTMENT OF THE NAVY

COMMANDING OFFICER  
TRARON EIGHT SIX  
390 SAN CARLOS RD SUITE G  
PENSACOLA FLORIDA 32508-5503

IN REPLY REFER TO

TRARONEIGHTSIXINST 11320.1Q

N2

22 OCT 2015

TRARON EIGHT SIX INSTRUCTION 11320.1Q

From: Commanding Officer, Training Squadron EIGHT SIX

Subj: TRAINING SQUADRON EIGHT SIX FIRE BILL

Ref: (a) NASPNCLAINST 11320.1H

Encl: (1) Location of Fire Stations, Hangar 1854, Bldg. 3245,  
(2) Emergency Escape Routes Hangar 1854 North Side (2nd Deck)  
(3) Emergency Escape Routes Hangar 1854 South Side (2nd Deck)  
(4) Emergency Escape Routes Bldg. 3245

1. Purpose. To promulgate firefighting procedures for Training Squadron EIGHT SIX.

2. Cancellation. TRARONEIGHTSIXINST 11320.1P

3. Procedures for All Hands

a. Discovery of a Fire

(1) Any person discovering a fire, including extinguished fires, or having a reasonable suspicion that a fire exists will report it to the fire station immediately by use of a fire alarm box or telephone, ext. 452-3333.

(2) After reporting a fire, use whatever means are available to extinguish the fire, consistent with common safety sense, until the arrival of fire department personnel.

b. Fire Extinguishers

(1) Any person discharging a fire extinguisher, finding that a fire extinguisher has been used, or noting a damaged extinguisher shall report the fact immediately to the Consolidated Fire Department by calling 452-2898. Report this fact to the VT-86 Ground Safety Officer.

(2) All squadron fire extinguishers will be inspected once monthly by the Fire Marshall in compliance with reference (a).

(3) Fire extinguishers will not be removed from their assigned locations, except for firefighting without the approval of the VT-86 Ground Safety Officer.

c. Responsibilities

(1) Administrative Officer: Designate the VT-86 Ground Safety Officer as the Squadron Fire Warden whose duties and responsibilities are delineated in reference (a).

(2) All Hands

(a) The location and type of fire extinguishers are indicated in enclosure (1).

(b) When a fire alarm sounds, all personnel shall close all doors in their immediate area and evacuate the building in an expeditious and orderly manner, following the posted evacuation routes. Personnel in Hangar 1854 will muster by department in the parking lot southeast to Hangar 1854. The senior officer present will maintain order of the formation.

  
W. P. DONNELLY

Distribution:

Electronic only, via VT-86 Website:


<https://www.cnatra.navy.mil/tw6/vt86/Instructions.asp>

LOCATION AND TYPE OF FIRE EXTINGUISHERS, HANGAR 1854, BLDG 3245

| <u>TYPE</u> | <u>LOCATION</u>                          |
|-------------|--|
| CO2         | 1. <u>Hangar 1854 North Side (upper)</u> |
| CO2         | Passageway Outside Ready Room            |
| CO2         | Passageway Outside IGS Room              |
|             | 2. <u>Hangar 1854 South Side (lower)</u> |
| CO2         | Passageway Outside L3 Spaces             |
| CO2         | Passageway Outside RMS                   |
| CO2         | Passageway at the East Exit Doors        |
| CO2         | Passageway Outside Female Head           |
|             | 3. <u>Hangar 1854 South Side (upper)</u> |
| CO2         | Passageway Outside Perch                 |
| CO2         | Passageway Outside Student Control       |
| CO2         | Passageway Outside Male Head             |
|             | 4. <u>Bldg. 3245</u>                     |
| CO2         | Large Classroom North Side of Bldg.      |
| CO2         | Passageway Outside Admin                 |
| CO2         | Passageway at North Exit Doors           |





### BLDG 1854 NORTH SIDE FIRE EVACUATION





### BLDG 1854 SOUTH SIDE FIRE EVACUATION





# BLDG 3245 FIRE EVACUATION PLAN

